

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
127.2-20	Room 10 main	Sink	7:08	7084424		< 1.00
127.2-21	Room 10 bubbler	DF	7:09	7084425		< 1.00
127.2-22	Room 10 bathroom	Sink	7:10	7084424		1.20
127.2-23	Room 8 main	Sink	7:11	7084425		< 1.00
127.2-24	Room 8 bubbler	DF	7:12	7084426		< 1.00
127.2-25	Room 8 bathroom	Sink	7:13	7084427		1.10
127.2-26	Adult bathroom West side	Sink	7:14	7084428		2.90
127.2-27	Room 4A	Sink	7:15	7084429		1.90
127.2-28	Room 4 main	Sink	7:16	7084430		1.70
127.2-30	Room 4 bathroom	Sink	7:17	7084431+		11.6
127.2-31	Room 2 main	Sink	7:18	7084432		< 1.00
127.2-32	Room 2 bubbler	DF	7:19	7084433		1.70
127.2-33	Room 2 bath	Sink	7:20	7084434		2.20
127.2-34	Girls locker room main	Sink	7:21	7084435		11.6
127.2-35	Girls locker room bubbler	DF	7:22	7084436		3.90
127.2-36	Girls locker room Office	Sink	7:23	7084437		7.00
127.2-37	Fountain near locker room	DF	7:24	7084438		< 1.00
127.2-38	Bottle fill near locker room	DFB	7:25	7084439		< 1.00

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
127.2-58	Faculty bathroom near lib west 5th grade	Sink	7:44	7084458		<1.00
127.2-59	Fountain near library	DF	7:45	7084459		1.90
127.2-60	Room 22	Sink	7:46	7084460		<1.00
127.2-61	Kitchen kettle fill	Sink	7:47	7084461		2.40
127.2-62	Kitchen prep sink	Sink	7:48	7084462		2.00
127.2-63A	Girls Bath across from locker room single	Sink	7:49	7084463		2.70
127.2-63B	Girls Bath across from locker room dual left	Sink	7:50	7084464		1.40
127.2-63C	Girls Bath across from locker room dual right	Sink	7:51	7084465		1.00
127.2-64A	Boys Bath across from locker room single	Sink	7:52	7084466		1.40
127.2-64B	Boys Bath across from locker room dual Left	Sink	7:53	7084467		5.40
127.2-64C	Boys Bath across from locker room dual right	Sink	7:54	7084468		5.00
127.2-65A	Girls Bath near lib dual left	Sink	7:55	7084469		1.40
127.2-65B	Girls Bath near lib dual right	Sink	7:56	7084470		<1.00
127.2-66A	Boys Bath near lib dual left	Sink	7:57	7084471		3.30
127.2-66B	Boys Bath near lib dual left	Sink	7:58	7084472		2.20
127.2-67	Dish Wand	Sink	7:59	7084473		14.1

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
127.2-39	Boys locker room main	Sink	7:26	7084440		1.90
127.2-40	Boys locker room bubbler	DF	7:27	7084441		14.0
127.2-41	Boys locker room office	Sink	7:28	7084442		9.80
127.2-42	Dishwasher hand sink	Sink	7:29	7084443+		1.40
127.2-43	Kitchen 3 bay left	Sink	7:30	7084444		1.30
127.2-44	Kitchen 3 bay right	Sink	7:31	7084445		<1.00
127.2-45	Kitchen hand wash	Sink	7:32	7084446		<1.00
127.2-46	Receiving room	Sink	7:33	7084447		1.20
127.2-48	Faculty room	Sink	7:34	7084448		1.10
127.2-49	Room 29 main	Sink	7:35	7084449		<1.00
127.2-50	Room 29 bubbler	DF	7:36	7084450		2.80
127.2-51	Room 29 bathroom	Sink	7:37	7084451+		<1.00
127.2-52	Room 31 main	Sink	7:38	7084452		<1.00
127.2-53	Room 31 bubbler	DF	7:39	7084453		3.40
127.2-54	Room 31 bathroom	Sink	7:40	7084454+		<1.00
127.2-55	Room 31A	Sink	7:41	7084455		2.80
127.2-56	Faculty bathroom near lib east	Sink	7:42	7084456		1.80
127.2-57	Room 35	Sink	7:43	7084457		3.90

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
127.2-1	Main Office bathroom	Sink	6:50	7084404		9.90
127.2-2	Nurse exam room	Sink	6:51	7084405		9.70
127.2-3	Nurse bathroom	Sink	6:52	7084406		2.90
127.2-4	Speech room	Sink	6:53	7084407		3.50
127.2-5	Adult bathroom east side	Sink	6:54	7084408		1.00
127.2-6	Room 13 Main	Sink	6:55	7084409		5.60
127.2-7	Room 15 sink	Sink	6:56	7084410		<1.00
127.2-8	Room 15 bubbler	DF	6:57	7084411		1.00
127.2-9	Room 15 bathroom	Sink	6:58	7084412		2.30
127.2-10	Room 17 main	Sink	6:59	7084413		<1.00
127.2-12	Room 17 bathroom	Sink	7:00	7084414		1.00
127.2-13	Fountain outside 17	DF	7:01	7084415		<1.00
127.2-14	Room 14 main	Sink	7:02	7084416		<1.00
127.2-15	Room 14 bubbler	DF	7:03	7084417		3.00
127.2-16	Room 14 bathroom	Sink	7:04	7084418		1.20
127.2-17	Room 12 Main	Sink	7:05	7084419		<1.00
127.2-18	Room 12 bubbler	df	7:06	7084420		1.00
127.2-19	Room 12 bathroom	Sink	7:07	7084421		<1.00